



GENERAL NOTES

- 1. POLES ARE TO BE DESIGNED PER A.A.S.H.T.O. 80 SPECIFICATIONS.
- 2. ALL TUBING IS TO BE A.S.T.M. A500 GRADE B (46,000 P.S.I. MIN. YIELD).
- 3. ACCEPTED POLE MANUFACTURER: CEM-TEC CORPORATION OR APPROVED EQUAL.
- 4. ACCEPTED LUMINAIRE MANUFACTURER:

 AMERICAN ELECTRIC SERIES 153/154 OR G.E. DECASHIELD Ⅲ,

 OR APPROVED EQUAL.
- 5. FOR PAINT SPECIFICATIONS SEE STREET LIGHTING SPECIFICATION.

FOUNDATION NOTES

- 1. 3000 P.S.I. CLASS A CONCRETE PLACED NEXT TO UNDISTURBED EARTH.
- 2. 4 7/8 " x 36" GALVANIZED ANCHOR BOLTS WITH LEVELING NUTS & WASHERS. TACK WELD NUTS TO WASHERS AND WASHERS TO BASE PLATE AFTER TIGHTENING. (2 1/2 " PROJECTION)
- 3. 1 1/2 " THICK EMBECO GROUT #636 OR APPROVED EQUAL.
- 4. UNSTABLE SOILS, AND/OR POLE HEIGHTS OVER 40', SHALL REQUIRE SPECIAL ENGINEERING.
- 5. A 25' COIL OF NO. 4 STRANDED A.W.G. BARE COPPER CONDUCTOR SHALL BE INSTALLED BEFORE THE CONCRETE IS POURED. IT SHALL BE CONNECTED TO POLE GROUNDING SCREW IN THE BASE OF THE POLE.
- 6. ALL FINISHED POLE FOUNDATIONS SHALL BE CHAMFERED, AND AT SIDEWALK GRADE UNLESS OTHERWISE NOTED.
- 7. THIS FOUNDATION MAY ALSO BE USED FOR DUAL MAST ARM POLES.

FOUNDATION SECTION